



DIMENSIONS IN mm			
A	430	Z	430
B	690	Y	260
C	960	X	270
D	1255	W	295
E	1550	V	295
F	2000	U	450

1. THE LAYOUT OF MAINS IS GENERALLY IN ACCORDANCE WITH THE 'REPORT OF JOINT COMMITTEE ON LOCATION OF UNDERGROUND SERVICES' PUBLISHED BY THE INSTITUTION OF CIVIL ENGINEERS.
2. THE DIMENSIONS SHOWN REPRESENT THE PREFERRED ARRANGEMENT IN STRAIGHT ROUTES ON RESIDENTIAL ESTATES. VARIATIONS MAY BE NECESSARY AT CURVES AND CHANGES OF GRADIENT.
3. THE SPACE ALLOCATED IS CONSIDERED TO BE THE ABSOLUTE MIN.
4. WHERE SERVICES ARE TO BE CONNECTED TO GAS MAINS A MINIMUM DISTANCE OF 2.0M IS REQUIRED BETWEEN THE BUILDING LINE AND THE CENTRE LINE OF THE MAIN.
5. REVISED IN LINE WITH IGE/TD/3, DEPTH OF COVER OF GAS MAINS IN FOOTWAY - 600MM; DEPTH OF COVER OF GAS MAINS IN ROADWAY - 750MM.

NOTES:

1. ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.
2. DO NOT SCALE FROM THIS DRAWING.

Rev	Description	Drawn	Checked	Approved	Date
0	FINAL	KLH	ACB	GW	23.06.10

south east water

SOUTH EAST WATER PLC
ROCFORT RD
SNODLAND
KENT ME6 5AH

TEL: 0845 2235111
FAX: 01634 873910

STANDARD DETAILS

JOB TITLE

NJUG LAYOUT FOR UTILITIES
IN FOOTPATHS

SCALE

N.T.S

DRAWN

KLH

DATE

23.06.10

DRAWING No.

67344/015

REVISION

0