


750 MIN

2. DO NOT SCALE FROM THIS DRAWING.

. ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

DO NOT SCALE - IF IN DOUBT ASK

В



TYPICAL METER MANIFOLD ARRANGEMENT

NOTES: 1. CHAMBER SIZE IS DEPENDANT UPON NUMBER OF METERS & MAY BE REVISED

ACCORDINGLY.

D

NOTES:

1. THIS METER CHAMBER TO BE USED IN AREAS SUBJECT TO TRAFFIC LOADING
2. METER TO BE POSITIONED CENTRALLY WITHIN CHAMBER

— BS 5433 STOP VALVES FEMALE IRON OUTLETS WITH REDUCING BUSHES TO METER TAILS IF REQUIRED. NOT REQUIRED ON 25mm. METER BYPASS PIPEWORK AND ISOLATION VALVE FLOW 180 PLASTIC CHAMBER
- SECTIONS USE 610 x
455 SECTIONS FOR
25mm AND 900 x 600
FOR 40mm AND ABOVE - DUCTILE IRON
COVER AND FRAME
CLEAR OPENING 入く入く入く PLASTIC BEARING SLAB METER SUPPORT PLINTH HEAD STOP TAP 18mm SQUARE **GRANULAR MATERIAL** WELL COMPACTED CLASS M1 MORTAR BED TO FRAME 600x450 CLASS D400 FIELD

С

south east water

SOUTH EAST WATER PLC ROCFORT RD SNODLAND SNODLAND KENT ME6 5AH

STANDARD DETAILS

BOUNDARY BOX FOR METER CHAMBER / METER > 25mm

67344/018 23.06.10 A3

NIS