



## NOTES:

- 1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE
- 2. DO NOT SCALE FROM THIS DRAWING
- 3. PRE-CAST CONCRETE SECTIONS AND ADAPTER SLABS IN ACCORDANCE WITH BS 5834: PART 4
- 4. COVER ARRANGEMENT SHOWN FOR LAND TYPES WHERE COVER TO BE FLUSH WITH SURROUNDING GROUND LEVEL e.g. HIGHWAY.
- 5. FOR AGRICULTURAL LAND COVER TO BE HIGHER THAN SURROUNDING GROUND LEVEL.
- 6. CHAMBER SIZE IS DEPENDENT UPON VALVE/METER SIZE
- 7. MINIMUM CHAMBER DIAMETER TO BE NOT LESS THAN 1200mm
- 8. DEPTH OF CHAMBER TO BE SPECIFIED.
- 9. FOR VALVES/METERS UPTO 250mm DIA. 600 x 900 RECTANGULAR CHAMBER TO BE USED.
- 10. FOR FLOW METERS DIMENSION L TO BE METER OD + 600mm FOR FLOWMETER CALIBRATION INSTRUMENT.

